Tablet Chlorination

Richard Weaver and Bruce Lesikar

Note: The following is taken from a fact sheet produced by the Texas A&M University System.

Where regulations allow treated wastewater to be land applied, it first must be disinfected to prevent odors and remove disease-causing microorganisms. Wastewater can be disinfected with chlorine, ozone, and ultraviolet light. For onsite wastewater treatment systems, the most common form of disinfection is tablet chlorination.

Tablet chlorinators generally have four components:

- chlorine tablets,
- a tube holding the tablets,
- a contact device that puts the chlorine tablets into contact with the wastewater, and
- a storage reservoir, usually a pump tank, where the wastewater is stored before it is distributed.

Before being chlorinated, wastewater from a home is treated by a secondary treatment device, usually in an aerobic treatment unit or sand filter. The wastewater moves from the treatment device through a pipe to the contact device.

The contact device usually contains a basin where the tube containing a stack of chlorine tablets is placed. The bottom tablet in the tube is in contact with the wastewater flowing through the basin. As that tablet dissolves and/or erodes, the tablet above falls by gravity to replace it.

A tablet can dissolve quickly or slowly, depending on the amount of wastewater coming into contact with it and the length of time it is in contact. A balance must be struck regarding the contact time in the chlorinator basin: too much contact time causes the wastewater to be overchlorinated and the tablets to be consumed rapidly; too little contact time, and the wastewater is not chlorinated enough.

Use only chlorine tablets that are approved for use in wastewater. They are made of calcium hypochlorite, a common household bleach. These tablets dissolve in the wastewater, releasing the hypochlorite, which then

becomes hypochlorous acid, the primary disinfectant.

Do not use swimming pool chlorine tablets. They are often made from trichloroisocyanuric acid, which is not approved for use in wastewater treatment systems. These tablets make the chlorine available too slowly for it to be effective. If wetted repeatedly, they also can produce nitrogen chloride, which can explode.

Do not combine tablets of trichloroisocyanuric acid with calcium hypochlorite, because the combination will form the explosive compound nitrogen chloride. Read the list of active ingredients on the tablet label to make sure you are using calcium hypochlorite.

Because chlorine tablets are caustic, handle them with care. Wear gloves to protect your skin from direct contact with the tablets. Moist tablets are the most caustic; handle them with special care.

Also, because chlorine gas collects in the tablet container, open the container in a well-ventilated area. Chlorine gas can escape from the tablets and container, reducing the effectiveness of the tablets and possibly corroding metal products stored near the container.

After being chlorinated, the wastewater enters the pump tank, where the disinfection process is completed. At this point the wastewater is called reclaimed water.

An easy way to determine the chlorine concentration in your reclaimed water is by using chlorine test kits. They are available in stores that sell swimming pool supplies.

The most satisfactory kits require that you mix a small amount of reclaimed water in a solution and compare the mixture's color with those shown in the kit. The kits using paper strips may be less satisfactory because they do not determine the actual concentration of chlorine in the water.

Usually, if a test detects any chlorine, the wastewater will contain less than 200 fecal coliforms per 100 mil-



liliters. But this does not guarantee that it is free of disease-causing organisms. To reduce the risk of having any disease-causing organisms, the wastewater should have at least 0.2 milliliters of chlorine per liter.

Keep it Working

You can either buy a chlorinator commercially or have one built by an installer. Please follow the manufacturer's recommendations for maintaining the system.

- Make sure the chlorinator contains chlorine tablets at all times. Inspect it weekly to ensure that tablets are present and in contact with the wastewater. Add chlorine tablets as necessary. Just as cars do not operate without gasoline, tablet chlorinators do not operate without chlorine tablets.
- Tablets can become compacted in the tube. To reduce the chances of compaction, place two to five tablets in the tube at a time.
- If the tablets do become compacted in the tube, or if a portion of the bottom tablet has not dissolved and is holding up the rest of the stack, remove the tube and wash out the blockage with a stream of water from a garden hose.
- Use only tablets that have been certified for use in domestic wastewater systems. State regulations do not allow tablets for swimming pools and other applications to be used to treat wastewater.
- Use a chlorine test kit to determine the chlorine concentration in the pump.